

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7300-1516:102 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: AES Corporation, 285 Newbury Street, Peabody, MA 01960
Contact: Thomas Kenty (978) 535-7310 Fax (978) 535-7313

DESIGN: Model 7750F Subscriber Unit two way RF transceiver used with the AMSECO direct plug-in Class 2 transformer. Unit is intended for use with listee's separately listed Model IntelliNet 7700 system (7300-1516:101) . Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 16.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, and UL label.

APPROVAL: Listed as a two-way transceiver unit for use with separately listed compatible fire alarm control units.

07-03-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager